



January 11, 2022

Diane Czarnecki  
Industrial Hygienist  
Facilities Management Division  
GSA Public Buildings Service – Heartland Region  
2300 Main Street  
Kansas City, MO 64108

Re: Goodfellow Federal Center – Bldg. 105 Air Sampling  
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the Resource Conservation and Recovery Act (RCRA) metals air sampling investigation of the above referenced building located at the Goodfellow Federal Complex, in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide sampling data regarding existing conditions to supplement previous investigation reports prepared for the facility. The following report summarizes air-sample collection activities and the laboratory analytical results of the samples submitted.

## METHODOLOGY

On December 8, 2021, Emily Pulcher and Jeff Smith of Burns & McDonnell and OCCU-TEC conducted area air-sampling for the presence of seven (7) of the RCRA metals including arsenic, barium, cadmium, chromium, lead, selenium, and silver. Sampling was conducted in various locations throughout Building 105.

The sampling plan, number of samples, sample distribution, and general methodology was developed based on previous investigation methodology and in coordination with the GSA. Sample locations and samples collected from discretionary locations were determined by sampling personnel while on-site.

Air samples for RCRA metals were collected on 37-millimeter (mm) cassettes with 0.8 micrometer ( $\mu\text{m}$ ) mixed cellulose ester (MCE) filters, using powered air sampling pumps, in accordance with the National Institute for Occupational Safety and Health (NIOSH) Method 7300. The sampling strategy included collecting a minimum sample volume of 500 liters based on the calibrated pump flow rate and sample duration. Air samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independent analysis of 7 RCRA metals according to NIOSH method 7300. EHS is accredited under the American Industrial Hygiene Association (AIHA) Industrial Hygiene Laboratory Accreditation Program (IHLAP) program, identification number LAP-100420.



Diane Czarnecki  
Facilities Management Division  
January 11, 2022  
Page 2

## RESULTS AND DISCUSSION

Results of the air sampling are summarized in the table below by identifying the range of results for Building 105 for each of the seven (7) metals that were sampled. Results indicate that all 27 air samples collected from Building 105 and analyzed for RCRA metals were below their respective OSHA Permissible Exposure Limit (PEL), as based on a time-weighted-average.

**Table 1. Summary of Air Sampling Results**

Analyte	Lowest Concentration <sup>(a)</sup> ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>	Highest Concentration <sup>(a)</sup> ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>	Permissible Exposure Limit (PEL) ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>
Arsenic	<0.21	<0.30	10
Barium	<0.21	<0.30	500
Cadmium	<0.041	<0.059	5
Chromium (Total)	<1.1	<1.5	500
Lead	<0.21	<0.30	50
Selenium	<1.1	<1.5	200
Silver	<0.21	<0.30	10

Notes:

- (a) Samples with a “<” sign indicate that the results were below the laboratory’s reporting limit, which varies based on sample air volume.
- (b)  $\mu\text{g}/\text{m}^3$  = micrograms per cubic meter of air.

GSA may choose to compare results with guidance limits from additional organizations for risk evaluation, including but not limited to the American Conference of Governmental Industrial Hygienists (ACGIH) and/or the World Health Organization (WHO).

A summary table of all sampling results by location is included in Appendix A. The complete laboratory report for the air sampling from EHS is attached in Appendix B.

## LIMITATIONS

The scope of this assessment was limited as follows. Burns & McDonnell collected samples from a select number of locations in an effort to minimize cost while providing a general overview of the air quality at the site. Sample locations do not encompass every indoor space at the site. Additionally, based on previous sampling history, samples were only analyzed for a select number of potential contaminants likely to affect the air quality at the site. Burns &



Diane Czarnecki  
Facilities Management Division  
January 11, 2022  
Page 3

McDonnell is not responsible for potential contaminants not identified in this report. This report was prepared for the sole use of GSA.

Burns & McDonnell appreciates the opportunity to work with the General Services Administration on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

A large black rectangular redaction box covering several lines of text below the (b) (6) notation.

Matt Shanahan, CHMM  
Project Manager

Attachments:

- Appendix A – Results Summary by Location
- Appendix B – Air Sample Laboratory Report

Information in Appendices A and B is not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or [r6environmental@gsa.gov](mailto:r6environmental@gsa.gov).

## **APPENDIX A – RESULTS SUMMARY BY LOCATION**

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
105-A-01	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--
105-A-02	2nd floor, conference room 330, north table	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.056	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-03	2nd floor, office room 342, east wall	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-04	2nd floor, lab room 328, south wall	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.056	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-05	2nd floor, lab room 339, north wall	Arsenic	< 0.29	µg/m <sup>3</sup>	10
		Barium	< 0.29	µg/m <sup>3</sup>	500
		Cadmium	< 0.057	µg/m <sup>3</sup>	5
		Chromium	< 1.5	µg/m <sup>3</sup>	500
		Lead	< 0.29	µg/m <sup>3</sup>	50
		Selenium	< 1.5	µg/m <sup>3</sup>	200
		Silver	< 0.29	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
105-A-06	2nd floor, lab break room, east wall	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-07	2nd floor, compressed gas storage, room 320, center	Arsenic	< 0.30	µg/m <sup>3</sup>	10
		Barium	< 0.30	µg/m <sup>3</sup>	500
		Cadmium	< 0.059	µg/m <sup>3</sup>	5
		Chromium	< 1.5	µg/m <sup>3</sup>	500
		Lead	< 0.30	µg/m <sup>3</sup>	50
		Selenium	< 1.5	µg/m <sup>3</sup>	200
		Silver	< 0.30	µg/m <sup>3</sup>	10
105-A-08	2nd floor, east hallway, outside northeast lab doors	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-09	2nd floor, lab room 314, north wall	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.056	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-10	2nd floor, lab office 361, northeast corner	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
105-A-11	2nd floor, southwest lobby, window sill	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-12	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--
105-A-13	1st floor, lab processing, column B47, west table	Arsenic	< 0.21	µg	10
		Barium	< 0.21	µg	500
		Cadmium	< 0.042	µg	5
		Chromium	< 1.1	µg	500
		Lead	< 0.21	µg	50
		Selenium	< 1.1	µg	200
		Silver	< 0.21	µg	10
105-A-14	1st floor, warehouse, column E46, rack	Arsenic	< 0.23	µg/m <sup>3</sup>	10
		Barium	< 0.23	µg/m <sup>3</sup>	500
		Cadmium	< 0.045	µg/m <sup>3</sup>	5
		Chromium	< 1.2	µg/m <sup>3</sup>	500
		Lead	< 0.23	µg/m <sup>3</sup>	50
		Selenium	< 1.2	µg/m <sup>3</sup>	200
		Silver	< 0.23	µg/m <sup>3</sup>	10
105-A-15	1st floor, office area, column F53, top of safe	Arsenic	< 0.21	µg/m <sup>3</sup>	10
		Barium	< 0.21	µg/m <sup>3</sup>	500
		Cadmium	< 0.041	µg/m <sup>3</sup>	5
		Chromium	< 1.1	µg/m <sup>3</sup>	500
		Lead	< 0.21	µg/m <sup>3</sup>	50
		Selenium	< 1.1	µg/m <sup>3</sup>	200
		Silver	< 0.21	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
105-A-16	1st floor, southwest lobby, top of key box	Arsenic	< 0.21	µg/m <sup>3</sup>	10
		Barium	< 0.21	µg/m <sup>3</sup>	500
		Cadmium	< 0.042	µg/m <sup>3</sup>	5
		Chromium	< 1.1	µg/m <sup>3</sup>	500
		Lead	< 0.21	µg/m <sup>3</sup>	50
		Selenium	< 1.1	µg/m <sup>3</sup>	200
		Silver	< 0.21	µg/m <sup>3</sup>	10
105-A-17	1st floor, mail room, column B40, table	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-18	1st floor, office across from west doors, front reception desk	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
105-A-19	1st floor, west hallway, lock box, column G28	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.056	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-20	1st floor, cubicle at column D19	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
105-A-21	2nd floor, north lobby, hand rail	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.056	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-22	2nd floor, column F9, top of cubicle	Arsenic	< 0.29	µg/m <sup>3</sup>	10
		Barium	< 0.29	µg/m <sup>3</sup>	500
		Cadmium	< 0.058	µg/m <sup>3</sup>	5
		Chromium	< 1.5	µg/m <sup>3</sup>	500
		Lead	< 0.29	µg/m <sup>3</sup>	50
		Selenium	< 1.5	µg/m <sup>3</sup>	200
		Silver	< 0.29	µg/m <sup>3</sup>	10
105-A-23	2nd floor, reception desk, column H17	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
105-A-24	1st floor, break room, column B9	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-25	2nd floor, printer cabinet, column C24	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
105-A-26	2nd floor, filing cabinet, column B35	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
105-A-27	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--

Notes:

<sup>1</sup>Limits equal to the Occupational Safety and Health Administration (OSHA) Permissible Exposure Limits (PELs)

**APPENDIX B – AIR SAMPLE LABORATORY REPORT**



Environmental Hazards Services, L.L.C.

7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Air Metals Analysis Report

Client:	Burns & McDonnell Engineering 9400 Ward Pkwy. Kansas City, MO 64114	Report Number:	21-12-01832
		Received Date:	12/13/2021
		Reported Date:	12/20/2021

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Client Number:  
26-3514

## Laboratory Results

Fax Number:  
816-822-3494

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
21-12-01832-001	105-A-01	12/17/2021	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	
21-12-01832-002	105-A-02	12/17/2021	Arsenic (As)	537	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
21-12-01832-003	105-A-03	12/17/2021	Arsenic (As)	555	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-12-01832

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
21-12-01832-004	105-A-04	12/17/2021	Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	540	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
21-12-01832-005	105-A-05	12/17/2021	Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	535	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
21-12-01832-006	105-A-06	12/17/2021	Arsenic (As)	548	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-12-01832

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
21-12-01832-007	105-A-07	12/17/2021	Arsenic (As)	517	<0.15	<0.30	
			Barium (Ba)		<0.15	<0.30	
			Cadmium (Cd)		<0.030	<0.059	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.30	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.30	
21-12-01832-008	105-A-08	12/17/2021	Arsenic (As)	548	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
21-12-01832-009	105-A-09	12/17/2021	Arsenic (As)	537	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
21-12-01832-010	105-A-10	12/17/2021	Arsenic (As)	548	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-12-01832

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
21-12-01832-011	105-A-11	12/17/2021	Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	546	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
21-12-01832-012	105-A-12	12/17/2021	Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	
21-12-01832-013	105-A-13	12/17/2021	Arsenic (As)	731	<0.15	<0.21	
			Barium (Ba)		<0.15	<0.21	
			Cadmium (Cd)		<0.030	<0.042	
			Chromium (Cr)		<0.75	<1.1	
			Lead (Pb)		<0.15	<0.21	
			Selenium (Se)		<0.75	<1.1	
			Silver (Ag)		<0.15	<0.21	
21-12-01832-014	105-A-14	12/17/2021	Arsenic (As)	679	<0.15	<0.23	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-12-01832

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
21-12-01832-015	105-A-15	12/17/2021	Barium (Ba)		<0.15	<0.23	
			Cadmium (Cd)		<0.030	<0.045	
			Chromium (Cr)		<0.75	<1.2	
			Lead (Pb)		<0.15	<0.23	
			Selenium (Se)		<0.75	<1.2	
			Silver (Ag)		<0.15	<0.23	
			Arsenic (As)	745	<0.15	<0.21	
			Barium (Ba)		<0.15	<0.21	
			Cadmium (Cd)		<0.030	<0.041	
			Chromium (Cr)		<0.75	<1.1	
21-12-01832-016	105-A-16	12/17/2021	Lead (Pb)		<0.15	<0.21	
			Selenium (Se)		<0.75	<1.1	
			Silver (Ag)		<0.15	<0.21	
			Arsenic (As)	719	<0.15	<0.21	
			Barium (Ba)		<0.15	<0.21	
			Cadmium (Cd)		<0.030	<0.042	
			Chromium (Cr)		<0.75	<1.1	
			Lead (Pb)		<0.15	<0.21	
			Selenium (Se)		<0.75	<1.1	
			Silver (Ag)		<0.15	<0.21	
21-12-01832-017	105-A-17	12/17/2021	Arsenic (As)	555	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-12-01832

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
21-12-01832-018	105-A-18	12/17/2021	Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	558	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
			Arsenic (As)	540	<0.15	<0.28	
21-12-01832-019	105-A-19	12/17/2021	Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	547	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
21-12-01832-020	105-A-20	12/17/2021	Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	547	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
21-12-01832-021	105-A-21	12/17/2021	Arsenic (As)	545	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-12-01832

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
21-12-01832-022	105-A-22	12/17/2021	Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	525	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.058	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
21-12-01832-023	105-A-23	12/17/2021	Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
			Arsenic (As)	558	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
			Arsenic (As)	548	<0.15	<0.28	
21-12-01832-024	105-A-24	12/17/2021	Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-12-01832

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
21-12-01832-025	105-A-25	12/17/2021	Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	549	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
21-12-01832-026	105-A-26	12/17/2021	Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	551	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
21-12-01832-027	105-A-27	12/17/2021	Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 21-12-01832

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
-------------------	----------------------	---------------	---------	----------------	------------------	-----------------------	--------------

## Sample Narratives:

Method: NIOSH 7300M  
Analyst: Kailee Guthrie

(b) (6)

Reviewed By Authorized Signatory:

*Tasha Eaddy*  
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. These sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of Environmental Hazards Services, L.L.C. NY ELAP #11714.

**LEGEND**      ug = microgram      ug/m<sup>3</sup> = micrograms per cubic meter  
                 mL = milliliter      L = Liters

# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Metals Chain of Custody Form

Pg 1 of 2

Company Name	Burns & McDonnell						Account #	26-3514								
Company Address	9400 Ward Parkway						City/State/Zip	Kansas City, MO 64114								
Phone	314-302-4661						Email	eapulcher@burnsmcd.com								
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd														
PO Number	168765			Collected By	Emily Pulcher & Jeff Smith											
Turn-Around Time	<input checked="" type="radio"/> 5 DAY <input type="radio"/> 3 DAY <input type="radio"/> 2 DAY <input type="radio"/> 1 DAY <input type="radio"/> SAME DAY OR WEEKEND - Must Call Ahead															
LAB NUMBER	Client Sample ID	Collection Date & Time	METALS				Other Metals	PARTICULATES			AIR			WIPES		
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile		Welding Fume Profile	TX 11 TCLP	CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric		TSP Pb	PM-10
1	105-A-01	12/8/21 0725											NA	NA	NA	x
2	105-A-02		0744										216	2.5	537	x
3	105-A-03		0745										216	2.6	555	x
4	105-A-04		0746										216	2.5	540	x
5	105-A-05		0748										215	2.5	535	x
6	105-A-06		0749										215	2.6	548	x
7	105-A-07		0750										215	2.4	517	x
8	105-A-08		0752										214	2.6	548	x
9	105-A-09		0754										214	2.5	537	x
10	105-A-10		0756										216	2.5	548	x
11	105-A-11		0757										215	2.5	546	x
12	105-A-12		0725										NA	NA	NA	x
13	105-A-13		0800										286	2.6	731	x
14	105-A-14		0801										271	2.5	679	x
15	105-A-15		0803										286	2.6	745	x
Released By:			Emily Pulcher			Date:	12/9/21			Time:	1600					
Signature:			(b) (6)													

LAB USE ONLY – BELOW THIS LINE

Received By: B. Stone

(b) (6)

Signature: \_\_\_\_\_

Date: 11/13/21 Time: 101  AM  PM

Portal Contact Added

 7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

 RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

21-12-01832



Due Date:

12/20/2021

(Monday)

EL

MM-L

# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Metals Chain of Custody Form

Pg 2 of 2

Company Name	Burns & McDonnell						Account #	26-3514								
Company Address	9400 Ward Parkway						City/State/Zip	Kansas City, MO 64114								
Phone	314-302-4661						Email	eapulcher@burnsmcd.com								
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd														
PO Number	168765			Collected By	Emily Pulcher & Jeff Smith											
Turn-Around Time	<input checked="" type="radio"/> 5 DAY		<input type="radio"/> 3 DAY	<input type="radio"/> 2 DAY	<input type="radio"/> 1 DAY	<input type="radio"/> SAME DAY OR WEEKEND - Must Call Ahead										
LAB NUMBER	Client Sample ID	Collection Date & Time	METALS				Other Metals	PARTICULATES			AIR			WIPES		
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile		Welding Fume Profile	TX 11 TCLP	CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric		TSP Pb	PM-10
1	105-A-16	12/8/21 0805											284	2.5	719	x
2	105-A-17	1139											222	2.5	555	x
3	105-A-18	1142											220	2.5	558	x
4	105-A-19	1143											220	2.5	540	x
5	105-A-20	1145											220	2.5	547	x
6	105-A-21	1154											215	2.5	545	x
7	105-A-22	1155											215	2.4	525	x
8	105-A-23	1157											215	2.6	558	x
9	105-A-24	1148											218	2.5	548	x
10	105-A-25	1158											214	2.6	549	x
11	105-A-26	1200											214	2.6	551	x
12	105-A-27	0725											NA	NA	NA	x
13																x
14																x
15																x
Released By:	Emily Pulcher				Date:	12/9/21			Time:	1600						
Signature:	(b) (6)															

LAB USE ONLY – BELOW THIS LINE

Received By: T Stone

(b) (6)

Signature:

Date: 12/17/21 Time: 101  AM  PM

Portal Contact Added

 7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

 RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

