



January 20, 2021

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service – Heartland Region
2300 Main Street
Kansas City, MO 64108

Re: Goodfellow Federal Center – Bldg. 104 Air Sampling
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the Resource Conservation and Recovery Act (RCRA) metals air sampling investigation of the above referenced building located at the Goodfellow Federal Complex, in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide sampling data regarding existing conditions to supplement previous investigation reports prepared for the facility. The following report summarizes air-sample collection activities and the laboratory analytical results of the samples submitted.

METHODOLOGY

On December 1, 2020, Emily Ahlemeyer of Burns & McDonnell and Jeff Smith of OCCU-TEC conducted area air-sampling for the presence of seven (7) of the RCRA metals including arsenic, barium, cadmium, chromium, lead, selenium, and silver. Sampling was conducted in various locations throughout Building 104.

The sampling scheme, number of samples, sample distribution, and general methodology was developed based on previous investigation methodology and in coordination with the GSA. Sample locations and samples collected from discretionary locations were determined by sampling personnel while on-site.

Air samples for RCRA metals were collected on 37-millimeter (mm) cassettes with 0.8 micrometer (μm) mixed cellulose ester (MCE) filters, using powered air sampling pumps, in accordance with the National Institute for Occupational Safety and Health (NIOSH) Method 7300. The sampling strategy included collecting a minimum sample volume of 500 liters based on the calibrated pump flow rate and sample duration. Air samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independent analysis of 7 RCRA metals according to NIOSH method 7300. EHS is accredited under the American Industrial Hygiene Association (AIHA) Industrial Hygiene Laboratory Accreditation Program (IHLAP) program, identification number LAP-100420.

Diane Czarnecki
 Facilities Management Division
 January 20, 2021
 Page 2

RESULTS AND DISCUSSION

Results of the air sampling are summarized in the table below by identifying the range of results for Building 104 for each of the seven (7) metals that were sampled. Results indicate that all 27 air samples collected from Building 104 and analyzed for RCRA metals were below their respective OSHA Permissible Exposure Limit (PEL), as based on a time-weighted-average.

Table 1. Summary of Air Sampling Results

Analyte	Lowest Concentration ^(a) ($\mu\text{g}/\text{m}^3$) ^(b)	Highest Concentration ^(a) ($\mu\text{g}/\text{m}^3$) ^(b)	Permissible Exposure Limit (PEL) ($\mu\text{g}/\text{m}^3$) ^(b)
Arsenic	<0.26	<0.31	10
Barium	<0.26	<0.31	500
Cadmium	<0.052	<0.062	5
Chromium (Total)	<1.3	<1.6	500
Lead	<0.26	<0.31	50
Selenium	<1.3	<1.6	200
Silver	<0.26	<0.31	10

Notes:

- (a) Samples with a “<” sign indicate that the results were below the laboratory’s reporting limit, which varies based on sample air volume.
- (b) $\mu\text{g}/\text{m}^3$ = micrograms per cubic meter of air.

GSA may choose to compare results with guidance limits from additional organizations for risk evaluation, including but not limited to the American Conference of Governmental Industrial Hygienists (ACGIH) and/or the World Health Organization (WHO).

A summary table of all sampling results by location is included in Appendix A. The complete laboratory report for the air sampling from EHS is attached in Appendix B. The air sampling professional’s Missouri Lead license is included in Appendix C.

LIMITATIONS

The scope of this assessment was limited as follows. Burns & McDonnell collected samples from a select number of locations in an effort to minimize cost while providing a general overview of the air quality at the site. Sample locations do not encompass every indoor space at the site. Additionally, based on previous sampling history, samples were only analyzed for a select number of potential contaminants likely to affect the air quality at the site. Burns &



Diane Czarnecki
Facilities Management Division
January 20, 2021
Page 3

McDonnell is not responsible for potential contaminants not identified in this report. This report was prepared for the sole use of GSA.

Burns & McDonnell appreciates the opportunity to work with the General Services Administration on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

A black rectangular redaction box covers the signature area, with the text "(b) (6)" written in the top left corner of the box.

Matt Shanahan, CHMM
Project Manager

Attachments:

- Appendix A – Results Summary by Location
- Appendix B – Air Sample Laboratory Report
- Appendix C – Licenses

Information in Appendices B and C is not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or r6environmental@gsa.gov.

APPENDIX A – RESULTS SUMMARY BY LOCATION

Appendix A

Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
104-A-01	1st floor, office area at column G2	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.053	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.27	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10
104-A-02	1st floor, break room at column F9	Arsenic	< 0.29	µg/m ³	10
		Barium	< 0.29	µg/m ³	500
		Cadmium	< 0.057	µg/m ³	5
		Chromium	< 1.5	µg/m ³	500
		Lead	< 0.29	µg/m ³	50
		Selenium	< 1.5	µg/m ³	200
		Silver	< 0.29	µg/m ³	10
104-A-03	1st floor, old stacks area at column B21	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.054	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.27	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10
104-A-04	1st floor, top of x-ray machine at column C4	Arsenic	< 0.29	µg/m ³	10
		Barium	< 0.29	µg/m ³	500
		Cadmium	< 0.057	µg/m ³	5
		Chromium	< 1.5	µg/m ³	500
		Lead	< 0.29	µg/m ³	50
		Selenium	< 1.5	µg/m ³	200
		Silver	< 0.29	µg/m ³	10
104-A-05	1st floor, warehouse at column B9	Arsenic	< 0.29	µg/m ³	10
		Barium	< 0.29	µg/m ³	500
		Cadmium	< 0.057	µg/m ³	5
		Chromium	< 1.5	µg/m ³	500
		Lead	< 0.29	µg/m ³	50
		Selenium	< 1.5	µg/m ³	200
		Silver	< 0.29	µg/m ³	10

Appendix A

Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
104-A-06	1st floor, north lobby by elevator	Arsenic	< 0.29	µg/m ³	10
		Barium	< 0.29	µg/m ³	500
		Cadmium	< 0.057	µg/m ³	5
		Chromium	< 1.5	µg/m ³	500
		Lead	< 0.29	µg/m ³	50
		Selenium	< 1.5	µg/m ³	200
		Silver	< 0.29	µg/m ³	10
104-A-07	1st floor, west stairwell to basement	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.054	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.27	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10
104-A-08	Basement at column J27	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.28	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
104-A-09	1st floor, old stacks area at column J33	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.28	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
104-A-10	1st floor, old stacks area at column J46	Arsenic	< 0.29	µg/m ³	10
		Barium	< 0.29	µg/m ³	500
		Cadmium	< 0.057	µg/m ³	5
		Chromium	< 1.5	µg/m ³	500
		Lead	< 0.29	µg/m ³	50
		Selenium	< 1.5	µg/m ³	200
		Silver	< 0.29	µg/m ³	10

Appendix A

Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
104-A-11	1st floor, elevator equipment room at column J52	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.28	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
104-A-12	1st floor, south lobby	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.28	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
104-A-13	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--
104-A-14	2nd floor, south elevator lobby	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.28	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
104-A-15	2nd floor, office at column D48	Arsenic	< 0.31	µg/m ³	10
		Barium	< 0.31	µg/m ³	500
		Cadmium	< 0.062	µg/m ³	5
		Chromium	< 1.6	µg/m ³	500
		Lead	< 0.31	µg/m ³	50
		Selenium	< 1.6	µg/m ³	200
		Silver	< 0.31	µg/m ³	10

Appendix A

Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
104-A-16	2nd floor, conference room at column G41	Arsenic	< 0.29	µg/m ³	10
		Barium	< 0.29	µg/m ³	500
		Cadmium	< 0.057	µg/m ³	5
		Chromium	< 1.5	µg/m ³	500
		Lead	< 0.29	µg/m ³	50
		Selenium	< 1.5	µg/m ³	200
		Silver	< 0.29	µg/m ³	10
104-A-17	Penthouse at column B45	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.28	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
104-A-18	2nd floor, hallway at column B40	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.28	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
104-A-19	2nd floor, break room at column B31	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.28	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
104-A-20R	2nd floor, office area at column E25	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.056	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.28	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10

Appendix A

Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
104-A-21	2nd floor, office at column G23	Arsenic	< 0.28	µg/m ³	10
		Barium	< 0.28	µg/m ³	500
		Cadmium	< 0.055	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.28	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.28	µg/m ³	10
104-A-22	2nd floor, office at column H18	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.054	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.27	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10
104-A-23R	2nd floor, stairwell at column B17	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.054	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.27	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10
104-A-24	2nd floor, office at column H9	Arsenic	< 0.27	µg/m ³	10
		Barium	< 0.27	µg/m ³	500
		Cadmium	< 0.054	µg/m ³	5
		Chromium	< 1.4	µg/m ³	500
		Lead	< 0.27	µg/m ³	50
		Selenium	< 1.4	µg/m ³	200
		Silver	< 0.27	µg/m ³	10
104-A-25	2nd floor, north stairwell	Arsenic	< 0.26	µg/m ³	10
		Barium	< 0.26	µg/m ³	500
		Cadmium	< 0.052	µg/m ³	5
		Chromium	< 1.3	µg/m ³	500
		Lead	< 0.26	µg/m ³	50
		Selenium	< 1.3	µg/m ³	200
		Silver	< 0.26	µg/m ³	10

Appendix A

Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits ¹
104-A-26	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--
104-A-27	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--

Notes:

¹Limits equal to the Occupational Safety and Health Administration (OSHA) Permissible Exposure Limits (PELs)

APPENDIX B – AIR SAMPLE LABORATORY REPORT



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Air Metals Analysis Report

Client: Burns & McDonnell Engineering
 9400 Ward Pkwy.
 Kansas City, MO 64114

Report Number: 20-12-00718
 Received Date: 12/07/2020
 Reported Date: 12/11/2020

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 104-A-01-104-A-27

Client Number:
26-3514

Fax Number:
816-822-3494

Laboratory Results

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
20-12-00718-001	104-A-01	12/10/2020	Arsenic (As)	571	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.053	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-00718-002	104-A-02	12/10/2020	Arsenic (As)	533	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
20-12-00718-003	104-A-03	12/10/2020	Arsenic (As)	558	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00718

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 104-A-01-104-A-27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-00718-004	104-A-04	12/10/2020	Arsenic (As)	534	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
20-12-00718-005	104-A-05	12/10/2020	Arsenic (As)	530	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
20-12-00718-006	104-A-06	12/10/2020	Arsenic (As)	531	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00718

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 104-A-01-104-A-27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
20-12-00718-007	104-A-07	12/10/2020	Arsenic (As)	559	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-00718-008	104-A-08	12/10/2020	Arsenic (As)	547	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00718-009	104-A-09	12/10/2020	Arsenic (As)	537	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00718-010	104-A-10	12/10/2020	Arsenic (As)	530	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00718

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 104-A-01-104-A-27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
20-12-00718-011	104-A-11	12/10/2020	Arsenic (As)	543	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00718-012	104-A-12	12/10/2020	Arsenic (As)	552	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00718-013	104-A-13	12/10/2020	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	
20-12-00718-014	104-A-14	12/10/2020	Arsenic (As)	545	<0.15	<0.28	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00718

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 104-A-01-104-A-27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00718-015	104-A-15	12/10/2020	Arsenic (As)	489	<0.15	<0.31	
			Barium (Ba)		<0.15	<0.31	
			Cadmium (Cd)		<0.030	<0.062	
			Chromium (Cr)		<0.75	<1.6	
			Lead (Pb)		<0.15	<0.31	
			Selenium (Se)		<0.75	<1.6	
			Silver (Ag)		<0.15	<0.31	
20-12-00718-016	104-A-16	12/10/2020	Arsenic (As)	530	<0.15	<0.29	
			Barium (Ba)		<0.15	<0.29	
			Cadmium (Cd)		<0.030	<0.057	
			Chromium (Cr)		<0.75	<1.5	
			Lead (Pb)		<0.15	<0.29	
			Selenium (Se)		<0.75	<1.5	
			Silver (Ag)		<0.15	<0.29	
20-12-00718-017	104-A-17	12/10/2020	Arsenic (As)	536	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00718

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 104-A-01-104-A-27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00718-018	104-A-18	12/10/2020	Arsenic (As)	539	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00718-019	104-A-19	12/10/2020	Arsenic (As)	536	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00718-020	104-A-20	12/10/2020	Arsenic (As)	544	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.056	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00718-021	104-A-21	12/10/2020	Arsenic (As)	554	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00718

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 104-A-01-104-A-27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
20-12-00718-022	104-A-22	12/10/2020	Arsenic (As)	560	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-00718-023	104-A-23	12/10/2020	Arsenic (As)	563	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-00718-024	104-A-24	12/10/2020	Arsenic (As)	565	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00718

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 104-A-01-104-A-27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
			Silver (Ag)		<0.15	<0.27	
20-12-00718-025	104-A-25	12/10/2020	Arsenic (As)	578	<0.15	<0.26	
			Barium (Ba)		<0.15	<0.26	
			Cadmium (Cd)		<0.030	<0.052	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.26	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.26	
20-12-00718-026	104-A-26	12/10/2020	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	
20-12-00718-027	104-A-27	12/10/2020	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	

Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-00718

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 104-A-01-104-A-27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m ³)	Narrative ID
-------------------	----------------------	---------------	---------	----------------	------------------	------------------------------------	--------------

Sample Narratives:

Method: NIOSH 7300M
Analyst: Brittany Meyer

(b) (6)

Reviewed By Authorized Signatory:

Missy Kanode
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. EHS sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714.

LEGEND	ug = microgram	ug/m ³ = micrograms per cubic meter
	mL = milliliter	L= Liters

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4661	Email	eaahlemeyer@burnsmcd.com
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd	
PO Number	168765	Collected By	Emily Ahlemeyer & Jeff Smith
Turn-Around Time	<input checked="" type="radio"/> 3 DAY <input type="radio"/> 2 DAY <input type="radio"/> 1 DAY <input type="radio"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES AREA <small>Circle The Unit of Measurement Used cm or in</small>	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA 17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate		Vol.
																Mins.	L/min.		Total Liters
1	104-A-01	12/1/2020 0805							Ag, As, Ba, Cd, Cr, Pb, Se						215	2.60	571	x	
2	104-A-02	0807												215	2.48	533	x		
3	104-A-03	0816												223	2.50	558	x		
4	104-A-04	0814												212	2.52	534	x		
5	104-A-05	0815												211	2.51	530	x		
6	104-A-06	0817												213	2.50	531	x		
7	104-A-07	0826												217	2.58	559	x		
8	104-A-08	0827												217	2.52	547	x		
9	104-A-09	0830												210	2.56	537	x		
10	104-A-10	0832												215	2.47	530	x		
11	104-A-11	0834												215	2.53	543	x		
12	104-A-12	0836												215	2.57	552	x		
13	104-A-13	0743												NA	NA	NA	x		
14	104-A-14	1215												210	2.60	545	x		
15	104-A-15	1216												211	2.32	489	x		

Released By: Emily Ahlemeyer	Date: 12/4/2020	Time: 1600
Signature: (b) (6)		

LAB USE ONLY - BELOW THIS LINE

Received By: TStone

Signature: (b) (6)

Date: 12/7/20 Time: 11:36 AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010
 RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

20-12-00718

Due Date:
12/10/2020
(Thursday)
EL

ENVIRONMENTAL HAZARDS SERVICES, LLC

Metals Chain of Custody Form

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4661	Email	eaahlemeyer@burnsmed.com
Project Name / Testing Address		GFC / 4300 Goodfellow Blvd	
PO Number	108765	Collected By	Emily Ahlemeyer & Jeff Smith
Turn-Around Time	<input checked="" type="radio"/> 3 DAY <input type="radio"/> 2 DAY <input type="radio"/> 1 DAY <input type="radio"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES					AIR			WIPES AREA Circle The Unit of Measurement Used cm or in	
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		CA17 Total	Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate		Vol.
																Mins.	L/min.		Total Liters
1	104-A-16	12/1/2020 1217							Ag, As, Ba, Cd, Cr, Pb, Se						212	2.50	536	x	
2	104-A-17	↓ 1220							↓						215	2.50	536	x	
3	104-A-18	↓ 1224													214	2.52	539	x	
4	104-A-19	↓ 1226													209 214	2.51	536	x	
5	104-A-20R	12/2/2020 1106													220 209	2.61	544	x	
6	104-A-21	12/1/2020 1229													220	2.52	554	x	
7	104-A-22	↓ 1231													209 226	2.55	560	x	
8	104-A-23R	12/2/2020 1109													223 209	2.70	563	x	
9	104-A-24	12/1/2020 1237													223	2.54	565	x	
10	104-A-25	↓ 1239													224	2.58	578	x	
11	104-A-26	↓ 0925													NA	NA	NA	x	
12	104-A-27	↓ 0927													NA	NA	NA	x	
13																		x	
14																		x	
15																		x	

Released By: Emily Ahlemeyer	Date: 12/4/2020	Time: 1600
Signature: (b) (6)		

LAB USE ONLY - BELOW THIS LINE

Received By: TStone

Signature: (b) (6)

Date: 12/7/20 Time: 11:36 AM PM

Portal Contact Added

7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010
 RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

718

EHS
Laboratories™

Attach Laboratory Label Here

APPENDIX C – LICENSES

**STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES**

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Jeffrey T. Smith

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **3/16/2019**
Expiration Date: **3/16/2021**
License Number: **010316-200089640**



(b) (6)

Randall W. Williams, MD, FACOG
Director
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102