



January 20, 2021

Diane Czarnecki  
Industrial Hygienist  
Facilities Management Division  
GSA Public Buildings Service – Heartland Region  
2300 Main Street  
Kansas City, MO 64108

Re: Goodfellow Federal Center – Bldg. 110 Air Sampling  
Project No. 121244

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the Resource Conservation and Recovery Act (RCRA) metals air sampling investigation of the above referenced building located at the Goodfellow Federal Complex, in St. Louis, Missouri. Burns & McDonnell understands that the purpose of the investigation was to provide sampling data regarding existing conditions to supplement previous investigation reports prepared for the facility. The following report summarizes air-sample collection activities and the laboratory analytical results of the samples submitted.

## METHODOLOGY

On December 9, 2020, Emily Ahlemeyer of Burns & McDonnell and Eric Wenger of Burns & McDonnell conducted area air-sampling for the presence of seven (7) of the RCRA metals including arsenic, barium, cadmium, chromium, lead, selenium, and silver. Sampling was conducted in various locations throughout Building 110.

The sampling scheme, number of samples, sample distribution, and general methodology was developed based on previous investigation methodology and in coordination with the GSA. Sample locations and samples collected from discretionary locations were determined by sampling personnel while on-site.

Air samples for RCRA metals were collected on 37-millimeter (mm) cassettes with 0.8 micrometer ( $\mu\text{m}$ ) mixed cellulose ester (MCE) filters, using powered air sampling pumps, in accordance with the National Institute for Occupational Safety and Health (NIOSH) Method 7300. The sampling strategy included collecting a minimum sample volume of 500 liters based on the calibrated pump flow rate and sample duration. Air samples were submitted under chain-of-custody to Environmental Hazards Services, LLC (EHS) in Richmond, Virginia for independent analysis of 7 RCRA metals according to NIOSH method 7300. EHS is accredited under the American Industrial Hygiene Association (AIHA) Industrial Hygiene Laboratory Accreditation Program (IHLAP) program, identification number LAP-100420.



Diane Czarnecki  
Facilities Management Division  
January 20, 2021  
Page 2

## RESULTS AND DISCUSSION

Results of the air sampling are summarized in the table below by identifying the range of results for Building 110 for each of the seven (7) metals that were sampled. Results indicate that all 27 air samples collected from Building 110 and analyzed for RCRA metals were below their respective OSHA Permissible Exposure Limit (PEL), as based on a time-weighted-average.

**Table 1. Summary of Air Sampling Results**

Analyte	Lowest Concentration <sup>(a)</sup> ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>	Highest Concentration <sup>(a)</sup> ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>	Permissible Exposure Limit (PEL) ( $\mu\text{g}/\text{m}^3$ ) <sup>(b)</sup>
Arsenic	<0.26	<0.28	10
Barium	<0.26	<0.28	500
Cadmium	<0.051	<0.055	5
Chromium (Total)	<1.3	<1.4	500
Lead	<0.26	<0.28	50
Selenium	<1.3	<1.4	200
Silver	<0.26	<0.28	10

Notes:

- (a) Samples with a “<” sign indicate that the results were below the laboratory’s reporting limit, which varies based on sample air volume.
- (b)  $\mu\text{g}/\text{m}^3$  = micrograms per cubic meter of air.

GSA may choose to compare results with guidance limits from additional organizations for risk evaluation, including but not limited to the American Conference of Governmental Industrial Hygienists (ACGIH) and/or the World Health Organization (WHO).

A summary table of all sampling results by location is included in Appendix A. The complete laboratory report for the air sampling from EHS is attached in Appendix B. The air sampling professional’s Missouri Lead license is included in Appendix C.

## LIMITATIONS

The scope of this assessment was limited as follows. Burns & McDonnell collected samples from a select number of locations in an effort to minimize cost while providing a general overview of the air quality at the site. Sample locations do not encompass every indoor space at the site. Additionally, based on previous sampling history, samples were only analyzed for a select number of potential contaminants likely to affect the air quality at the site. Burns &



Diane Czarnecki  
Facilities Management Division  
January 20, 2021  
Page 3

McDonnell is not responsible for potential contaminants not identified in this report. This report was prepared for the sole use of GSA.

Burns & McDonnell appreciates the opportunity to work with the General Services Administration on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

A solid black rectangular box used to redact a signature.

Matt Shanahan, CHMM  
Project Manager

Attachments:

- Appendix A – Results Summary by Location
- Appendix B – Air Sample Laboratory Report
- Appendix C – Licenses

Information in Appendices B and C is not accessible for people using screen reader technology. If this information is required, it can be furnished upon request by contacting 816-223-6198 or [r6environmental@gsa.gov](mailto:r6environmental@gsa.gov).

## **APPENDIX A – RESULTS SUMMARY BY LOCATION**

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
110-A-01	1st floor, north loading dock, column A5	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.053	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-02	2nd floor, column L1	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-03	1st floor, break room, column F10	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.053	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-04	1st floor, column A11	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-05	1st floor, column E11	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
110-A-06	1st floor, column K13	Arsenic	< 0.26	µg/m <sup>3</sup>	10
		Barium	< 0.26	µg/m <sup>3</sup>	500
		Cadmium	< 0.052	µg/m <sup>3</sup>	5
		Chromium	< 1.3	µg/m <sup>3</sup>	500
		Lead	< 0.26	µg/m <sup>3</sup>	50
		Selenium	< 1.3	µg/m <sup>3</sup>	200
		Silver	< 0.26	µg/m <sup>3</sup>	10
110-A-07	1st floor, column P13	Arsenic	< 0.26	µg/m <sup>3</sup>	10
		Barium	< 0.26	µg/m <sup>3</sup>	500
		Cadmium	< 0.052	µg/m <sup>3</sup>	5
		Chromium	< 1.3	µg/m <sup>3</sup>	500
		Lead	< 0.26	µg/m <sup>3</sup>	50
		Selenium	< 1.3	µg/m <sup>3</sup>	200
		Silver	< 0.26	µg/m <sup>3</sup>	10
110-A-08	1st floor, column F15	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-09	1st floor, southeast stairwell	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-10	2nd floor, break room, column F10	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.053	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
110-A-11	2nd floor, column D16	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.053	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-12	2nd floor, electrical closet, column H14	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.053	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-13	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--
110-A-14	2nd floor, column E13	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-15	2nd floor, column G8	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
110-A-16	2nd floor, column E5	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-17	2nd floor, northwest corner of common area	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
110-A-18	2nd floor, column M12	Arsenic	< 0.28	µg/m <sup>3</sup>	10
		Barium	< 0.28	µg/m <sup>3</sup>	500
		Cadmium	< 0.055	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.28	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.28	µg/m <sup>3</sup>	10
110-A-19	2nd floor, column H15	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-20	Basement, column M17	Arsenic	< 0.26	µg/m <sup>3</sup>	10
		Barium	< 0.26	µg/m <sup>3</sup>	500
		Cadmium	< 0.051	µg/m <sup>3</sup>	5
		Chromium	< 1.3	µg/m <sup>3</sup>	500
		Lead	< 0.26	µg/m <sup>3</sup>	50
		Selenium	< 1.3	µg/m <sup>3</sup>	200
		Silver	< 0.26	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
110-A-21	Basement, column C9	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-22	ICE JV warehouse, outside office	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-23	ICE JV office	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-24	Goodwill office, break room	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.053	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10
110-A-25	ICE JV warehouse, east end	Arsenic	< 0.27	µg/m <sup>3</sup>	10
		Barium	< 0.27	µg/m <sup>3</sup>	500
		Cadmium	< 0.054	µg/m <sup>3</sup>	5
		Chromium	< 1.4	µg/m <sup>3</sup>	500
		Lead	< 0.27	µg/m <sup>3</sup>	50
		Selenium	< 1.4	µg/m <sup>3</sup>	200
		Silver	< 0.27	µg/m <sup>3</sup>	10

## Appendix A

### Results Summary by Location

Sample Number	Location	Analyte	Result	Units	Recommended Limits <sup>1</sup>
110-A-26	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--
110-A-27	Field blank	Arsenic	< 0.15	µg	--
		Barium	< 0.15	µg	--
		Cadmium	< 0.030	µg	--
		Chromium	< 0.75	µg	--
		Lead	< 0.15	µg	--
		Selenium	< 0.75	µg	--
		Silver	< 0.15	µg	--

Notes:

<sup>1</sup>Limits equal to the Occupational Safety and Health Administration (OSHA) Permissible Exposure Limits (PELs)

**APPENDIX B – AIR SAMPLE LABORATORY REPORT**



Environmental Hazards Services, L.L.C.

7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Air Metals Analysis Report

Client:	Burns & McDonnell Engineering 9400 Ward Pkwy. Kansas City, MO 64114	Report Number:	20-12-01810
		Received Date:	12/14/2020
		Reported Date:	12/17/2020

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 110-A-01-27

Client Number:  
26-3514

## Laboratory Results

Fax Number:  
816-822-3494

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
20-12-01810-001	110-A-01	12/16/2020	Arsenic (As)	568	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.053	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-002	110-A-02	12/16/2020	Arsenic (As)	561	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-003	110-A-03	12/16/2020	Arsenic (As)	572	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.053	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01810

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 110-A-01-  
27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
20-12-01810-004	110-A-04	12/16/2020	Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
			Arsenic (As)	563	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
20-12-01810-005	110-A-05	12/16/2020	Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
			Arsenic (As)	558	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-006	110-A-06	12/16/2020	Arsenic (As)	585	<0.15	<0.26	
			Barium (Ba)		<0.15	<0.26	
			Cadmium (Cd)		<0.030	<0.052	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.26	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.26	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01810

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 110-A-01-  
27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
20-12-01810-007	110-A-07	12/16/2020	Arsenic (As)	578	<0.15	<0.26	
			Barium (Ba)		<0.15	<0.26	
			Cadmium (Cd)		<0.030	<0.052	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.26	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.26	
20-12-01810-008	110-A-08	12/16/2020	Arsenic (As)	559	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-009	110-A-09	12/16/2020	Arsenic (As)	560	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-010	110-A-10	12/16/2020	Arsenic (As)	569	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.053	
			Chromium (Cr)		<0.75	<1.4	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01810

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 110-A-01-  
27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
20-12-01810-011	110-A-11	12/16/2020	Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
			Arsenic (As)	575	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.053	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
20-12-01810-012	110-A-12	12/16/2020	Silver (Ag)		<0.15	<0.27	
			Arsenic (As)	572	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.053	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-013	110-A-13	12/16/2020	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	
20-12-01810-014	110-A-14	12/16/2020	Arsenic (As)	563	<0.15	<0.27	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01810

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 110-A-01-  
27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-015	110-A-15	12/16/2020	Arsenic (As)	559	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-016	110-A-16	12/16/2020	Arsenic (As)	556	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-017	110-A-17	12/16/2020	Arsenic (As)	552	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01810

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 110-A-01-  
27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
20-12-01810-018	110-A-18	12/16/2020	Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	552	<0.15	<0.28	
			Barium (Ba)		<0.15	<0.28	
			Cadmium (Cd)		<0.030	<0.055	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.28	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.28	
			Arsenic (As)	558	<0.15	<0.27	
20-12-01810-019	110-A-19	12/16/2020	Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
			Arsenic (As)	597	<0.15	<0.26	
			Barium (Ba)		<0.15	<0.26	
			Cadmium (Cd)		<0.030	<0.051	
			Chromium (Cr)		<0.75	<1.3	
20-12-01810-020	110-A-20	12/16/2020	Lead (Pb)		<0.15	<0.26	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.26	
			Arsenic (As)	558	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.051	
			Chromium (Cr)		<0.75	<1.3	
			Lead (Pb)		<0.15	<0.26	
			Selenium (Se)		<0.75	<1.3	
			Silver (Ag)		<0.15	<0.26	
20-12-01810-021	110-A-21	12/16/2020	Arsenic (As)		<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01810

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 110-A-01-  
27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-022	110-A-22	12/16/2020	Arsenic (As)	561	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-023	110-A-23	12/16/2020	Arsenic (As)	556	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-024	110-A-24	12/16/2020	Arsenic (As)	572	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.053	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01810

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 110-A-01-  
27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m³)	Narrative ID
			Silver (Ag)		<0.15	<0.27	
20-12-01810-025	110-A-25	12/16/2020	Arsenic (As)	566	<0.15	<0.27	
			Barium (Ba)		<0.15	<0.27	
			Cadmium (Cd)		<0.030	<0.054	
			Chromium (Cr)		<0.75	<1.4	
			Lead (Pb)		<0.15	<0.27	
			Selenium (Se)		<0.75	<1.4	
			Silver (Ag)		<0.15	<0.27	
20-12-01810-026	110-A-26	12/16/2020	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	
20-12-01810-027	110-A-27	12/16/2020	Arsenic (As)	--	<0.15	---	
			Barium (Ba)		<0.15	---	
			Cadmium (Cd)		<0.030	---	
			Chromium (Cr)		<0.75	---	
			Lead (Pb)		<0.15	---	
			Selenium (Se)		<0.75	---	
			Silver (Ag)		<0.15	---	

# Environmental Hazards Services, L.L.C

Client Number: 26-3514

Report Number: 20-12-01810

Project/Test Address: 168765; GFC; 4300 Goodfellow Blvd.; 110-A-01-  
27

Lab Sample Number	Client Sample Number	Analyzed Date	Analyte	Air Volume (L)	Total Metal (ug)	Concentration (ug/m <sup>3</sup> )	Narrative ID
-------------------	----------------------	---------------	---------	----------------	------------------	------------------------------------	--------------

Sample Narratives:

Method: NIOSH 7300M  
Analyst: Brittany Meyer

(b) (6)

Reviewed By Authorized Signatory: \_\_\_\_\_

*Tasha Eaddy*  
QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contains less than the reporting limit for each particular metal, based on a 15mL volume. The reporting limit is 0.03ug for Cadmium, 0.15ug for Arsenic, Barium, Lead and Silver, and 0.75ug for Chromium and Selenium.

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Results represent the analysis of samples submitted by the client. Unless otherwise noted, samples are reported without a dry weight correction. Sample location, description, area, volume, etc., was provided by the client. If the report does not contain the result for a field blank, it is due to the fact that the client did not include a field blank with their samples. EHS sample results do not reflect blank correction. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714.

LEGEND                      ug = microgram                      ug/m<sup>3</sup> = micrograms per cubic meter  
                            mL = milliliter                      L= Liters

# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Metals Chain of Custody Form

Pg 1 of 2

Company Name	Burns & McDonnell						Account #	26-3514									
Company Address	9400 Ward Parkway						City/State/Zip	Kansas City, MO 64114									
Phone	314-302-4661						Email	eaahlemeyer@burnsmcd.com									
Project Name / Testing Address	GFC/4300 Goodfellow Blvd																
PO Number	168765			Collected By	Emily Ahlemeyer & Eric Wenger												
Turn-Around Time	<input checked="" type="checkbox"/> 3 DAY		<input type="checkbox"/> 2 DAY	<input type="checkbox"/> 1 DAY	<input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead												
LAB NUMBER	Client Sample ID	Collection Date & Time	METALS					PARTICULATES			AIR			WIPES			
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP	CA 17 Total	Other Metals	Total Nuisance Dust	Respirable Dust	TSP Gravimetric		TSP Pb	PM-10	Total Time
1	110-A-01	12/9/2020 0758												228	2.49	568	x
2	110-A-02		0801											224	2.51	561	x
3	110-A-03		0803											227	2.52	572	x
4	110-A-04		0805											226	2.49	563	x
5	110-A-05		0806											225	2.48	558	x
6	110-A-06		0807											232	2.52	585	x
7	110-A-07		0811											223	2.59	578	x
8	110-A-08		0812											223	2.51	559	x
9	110-A-09		0813											225	2.49	560	x
10	110-A-10		0816											229	2.49	569	x
11	110-A-11		0818											229	2.51	575	x
12	110-A-12		0820											227	2.52	572	x
13	110-A-13		0740											NA	NA	NA	x
14	110-A-14		1209											223	2.53	563	x
15	110-A-15		1211											222	2.52	559	x
Released By:			Emily Ahlemeyer			Date:	12/11/2020			Time:	1600						
Signature:			(b) (6)			LAB USE ONLY – BELOW THIS LINE											

Received By: TStone

(b) (6)

Signature: \_\_\_\_\_

Date: 12/14/20 Time: 12:33  AM  PM

Portal Contact Added

 7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010

 RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)

20-12-01810



Due Date:

12/17/2020

(Thursday)

EL

# ENVIRONMENTAL HAZARDS SERVICES, LLC

## Metals Chain of Custody Form

Pg 2 of 2

Company Name	Burns & McDonnell	Account #	26-3514
Company Address	9400 Ward Parkway	City/State/Zip	Kansas City, MO 64114
Phone	314-302-4661	Email	eaahlemeyer@burnsmcd.com

Project Name / Testing Address	GFC/4300 Goodfellow Blvd		
PO Number	168765	Collected By	Emily Ahlemeyer & Eric Wenger
Turn-Around Time	<input checked="" type="checkbox"/> 3 DAY <input type="checkbox"/> 2 DAY <input type="checkbox"/> 1 DAY <input type="checkbox"/> SAME DAY OR WEEKEND - Must Call Ahead		

LAB NUMBER	Client Sample ID	Collection Date & Time	METALS						Other Metals	PARTICULATES			AIR			WIPES		
			Pb TCLP	TCLP RCRA 8	RCRA 8 Total	Toxic Metal Profile	Welding Fume Profile	TX 11 TCLP		Total Nuisance Dust	Respirable Dust	TSP Gravimetric	TSP Pb	PM-10	Total Time	Flow Rate	Vol.	
1	110-A-16	12/9/2020 1212							Ag, As, Ba, Cd, Cr, Pb, Se						222	2.51	556	x
2	110-A-17			1213											222	2.49	552	x
3	110-A-18			1216											222	2.49	552	x
4	110-A-19			1216											223	2.50	558	x
5	110-A-20			1222											225	2.66	597	x
6	110-A-21			1222											224	2.49	558	x
7	110-A-22			1228											228	2.46	561	x
8	110-A-23			1230											227	2.45	556	x
9	110-A-24			1231											228	2.51	572	x
10	110-A-25			1234											226	2.50	566	x
11	110-A-26			1031											NA	NA	NA	x
12	110-A-27			1032											NA	NA	NA	x
13																		x
14																		x
15																		x

Released By:	Emily Ahlemeyer	Date:	12/11/2020	Time:	1600
Signature:	(b) (6)				

LAB USE ONLY – BELOW THIS LINE

Received By: TStone  
(b) (6)

Signature: \_\_\_\_\_  
Date: 12/14/20 Time: 12:33  AM  PM

Portal Contact Added

 7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4010  
 RESULTS VIA CLIENT PORTAL AVAILABLE @ [www.leadlab.com](http://www.leadlab.com)



Attach Laboratory Label Here

## **APPENDIX C – LICENSES**



**Missouri Department of Health  
and Senior Services**

(b) (6)

Lead Occupation License - ID Badge

License Number: 080311-300001861

**Lead Risk Assessor**

**Eric  
Wenger**

**Expiration Date: 03/11/2022**

**STATE OF MISSOURI**  
**DEPARTMENT OF HEALTH AND SENIOR SERVICES**

**LEAD OCCUPATION LICENSE REGISTRATION**

Issued to:

**Eric N. Wenger**

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

**Lead Risk Assessor**

Category of License

Issuance Date:

**3/11/2020**

Expiration Date:

**3/11/2022**

License Number:

**080311-300001861**



(b) (6)

Randall W. Williams, MD, FACOG  
Director  
Department of Health and Senior Services