



2604 NE Industrial Drive, Suite 230
North Kansas City, Missouri 64117
Telephone: 816.231.5580
Fax: 816.231.5641
www.occutec.com

November 14, 2019

Diane Czarnecki
Industrial Hygienist
Facilities Management Division
GSA Public Buildings Service - Heartland Region
2300 Main Street, Kansas City, MO 64108

**RE: Goodfellow Federal Center – Bldg. # 103 Drinking Water Sampling
Project # 919103**

Dear Ms. Czarnecki:

Thank you for the opportunity to provide the General Services Administration (GSA) with the above referenced environmental sampling activities. The following is our report.

INTRODUCTION

As requested, OCCU-TEC, Inc. (OCCU-TEC) conducted drinking water sampling for the presence of polychlorinated biphenyls (PCBs) and polycyclic aromatic hydrocarbons (PAHs) at Building #103 of the Goodfellow Federal Center (GFC) located at 4300 Goodfellow Federal Boulevard in St. Louis, Missouri. Sampling was completed in response to the ongoing environmental condition assessment at the GFC which is documented at the GFC Reading Room located at:
<https://www.gsa.gov/portal/content/212361>.

Drinking water sampling was conducted to determine the current levels of PCBs and PAHs in representative sources throughout the complex. Drinking water sampling at Bldg. #103 was conducted on September 19, 2019 by Mr. Austin O'Byrne of OCCU-TEC.

METHODOLOGY

The samples were collected individually labeled dedicated laboratory provided one (1) liter (L) glass amber bottles and 44.7 milliliter (mL) volatile organic analysis (VOA) vials with Teflon septa lined screw caps. One (1) liter bottles were filled to the shoulder and capped. VOA vials were filled until a positive meniscus was achieved, and the cap was placed on the vial to prevent airspace. One (1) liter bottles and VOA vials were preserved with laboratory provided preservative and placed on ice for shipment. The samples were then

shipped overnight to Eurofins-Eaton Analytical in South Bend, Indiana for analysis. Eurofins-Eaton Analytical is certified by the State of Missouri Department of Natural Resources (MDNR) as an approved drinking water laboratory. Eurofins-Eaton Analytical's Missouri Certification number is 880.

Drinking water sampling for the presence of PCBs and PAHs was conducted at fifteen (15) distinct locations within Building #103. A total of seventeen (17) samples were obtained including duplicate samples.

PCB samples were analyzed as per EPA Method 505 "Analysis of Organohalide Pesticides and Commercial Polychlorinated Biphenyl Products in water by Microextraction and Gas Chromatography." PAH samples were analyzed by EPA Method 525.2 "Determination of Organic Compounds in Drinking Water by Liquid-Solid Extraction and Capillary Column Gas Chromatography/Mass Spectrometry."

RESULTS AND DISCUSSION

A summary table of all sampling locations is included in Appendix A. The complete laboratory report for the drinking water sampling from Eurofins-Eaton Analytical is attached in Appendix B.

PCBs

All samples were below the maximum containment level (MCL) and the minimum reporting level (MRL) for the analytical method used.

PAHs

All samples were below the maximum containment level (MCL) and the minimum reporting level (MRL) for the analytical method used.

LIMITATIONS

The scope of this assessment was limited in nature. OCCU-TEC collected samples from a select number of drinking water sources in an effort to minimize cost while providing a general overview of the drinking water quality at the site. Sample locations do not encompass every drinking water source at the site. Samples were only analyzed for PCBs and PAHs in accordance with the scope of services requested by GSA. OCCU-TEC is not responsible for potential contaminants not identified in this report.

This report was prepared for the sole use of GSA. Reliance by any party other than GSA is expressly forbidden without OCCU-TEC's written permission. Any parties relying on

the report, with OCCU-TEC's written permission, are bound by the terms and conditions outlined in the original proposal as if said proposal was prepared for them.

OCCU-TEC appreciates the opportunity to work with the GSA on this project. Please contact us if you have any questions regarding this report or if we may be of any additional service.

Sincerely,

(b) (6)

Jeff T. Smith
Senior Project Manager

(b) (6)

Kevin Heriford
Environmental Operations Manager (QA/QC)

ATTACHMENTS

Appendix A, Sample Summary by Location
Appendix B, Water Sample Laboratory Report



Goodfellow Federal Center - Building 103

Sample Number	Location	Water Source	Analyte
103-W-01	2nd Floor Column H34 - Breakroom	Sink	PCBs ----- PAHs
103-W-02	2nd Floor Column H36 - Right Side	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-03	2nd Floor Column H36 - Left Side	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-04	2nd Floor Column B34 - Right Side	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-05	2nd Floor Column B34 - Right Side (Duplicate)	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-06	2nd Floor Column B34 - Left Side	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-07	1st Floor Column B34 - Right Side	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-08	1st Floor Column J34 - Right Side	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-09	2nd Floor Column C32	Sink	PCBs ----- PAHs
103-W-10	2nd Floor Column H6 - Left Side	Elkay Drinking Fountain	PCBs ----- PAHs
103-W-11	2nd Floor Column H6 - Right Side	Elkay Drinking Fountain	PCBs ----- PAHs
103-W-12	1st Floor Column G5 - Breakroom	Sink	PCBs ----- PAHs
103-W-13	2nd Floor Column B14 - Right Side	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-14	1st Floor Column B22 - Right Side	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-15	1st Floor Column B22 - Right Side (Duplicate)	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-16	1st Floor Column B22 - Left Side	Oasis Drinking Fountain	PCBs ----- PAHs
103-W-17	1st Floor Column B5 - Right Side	Oasis Drinking Fountain	PCBs ----- PAHs

LABORATORY REPORT

If you have any questions concerning this report, please do not hesitate to call us at (800) 332-4345 or (574) 233-4777.

This report may not be reproduced, except in full, without written approval from EEA.

STATE CERTIFICATION LIST

State	Certification	State	Certification
Alabama	40700	Missouri	880
Alaska	IN00035	Montana	CERT0026
Arizona	AZ0432	Nebraska	NE-OS-05-04
Arkansas	IN00035	Nevada	IN00035
California	2920	New Hampshire*	2124
Colorado	IN00035	New Jersey*	IN598
Colorado Radiochemistry	IN00035	New Mexico	IN00035
Connecticut	PH-0132	New York*	11398
Delaware	IN035	North Carolina	18700
Florida*	E87775	North Dakota	R-035
Georgia	929	Ohio	87775
Hawaii	IN035	Oklahoma	D9508
Idaho	IN00035	Oregon (Primary AB)*	4074
Illinois*	200001	Pennsylvania*	68-00466
Illinois Microbiology	17767	Puerto Rico	IN00035
Illinois Radiochemistry	IN00035	Rhode Island	LAO00343
Indiana Chemistry	C-71-01	South Carolina	95005
Indiana Microbiology	M-76-07	South Dakota	IN00035
Iowa	098	Tennessee	TN02973
Kansas*	E-10233	Texas*	T104704187-18-12
Kentucky	90056	Texas/TCEQ	TX207
Louisiana*	LA014	Utah*	IN00035
Maine	IN00035	Vermont	VT-8775
Maryland	209	Virginia*	460275
Massachusetts	M-IN035	Washington	C837
Michigan	9926	West Virginia	9927 C
Minnesota*	018-999-338	Wisconsin	999766900
Mississippi	IN035	Wyoming	IN035
EPA	IN00035		

*NELAP/TNI Recognized Accreditation Bodies

110 South Hill Street
 South Bend, IN 46617
 Tel: (574) 233-4777
 Fax: (574) 233-8207
 1 800 332 4345

Laboratory Report

Client: OCCU-TEC Inc.

Attn: Jeff Smith
 2604 NE Industrial Drive
 Suite 230
 North Kansas City, MO 64117

Report: 466036
 Priority: Standard Written
 Status: Final
 PWS ID: Not Supplied

Sample Information					
EEA ID #	Client ID	Method	Collected Date / Time	Collected By:	Received Date / Time
4428897	103-W-01	505	09/19/19 09:03	Client	09/20/19 10:00
4428914	103-W-01	525.2	09/19/19 09:03	Client	09/20/19 10:00
4428898	103-W-02	505	09/19/19 09:07	Client	09/20/19 10:00
4428915	103-W-02	525.2	09/19/19 09:07	Client	09/20/19 10:00
4428899	103-W-03	505	09/19/19 09:13	Client	09/20/19 10:00
4428916	103-W-03	525.2	09/19/19 09:13	Client	09/20/19 10:00
4428900	103-W-04	505	09/19/19 09:21	Client	09/20/19 10:00
4428917	103-W-04	525.2	09/19/19 09:21	Client	09/20/19 10:00
4428901	103-W-05	505	09/19/19 09:26	Client	09/20/19 10:00
4428918	103-W-05	525.2	09/19/19 09:26	Client	09/20/19 10:00
4428902	103-W-06	505	09/19/19 09:31	Client	09/20/19 10:00
4428919	103-W-06	525.2	09/19/19 09:31	Client	09/20/19 10:00
4428903	103-W-07	505	09/19/19 09:39	Client	09/20/19 10:00
4428920	103-W-07	525.2	09/19/19 09:39	Client	09/20/19 10:00
4428904	103-W-08	505	09/19/19 09:47	Client	09/20/19 10:00
4428921	103-W-08	525.2	09/19/19 09:47	Client	09/20/19 10:00
4428905	103-W-09	505	09/19/19 11:04	Client	09/20/19 10:00
4428922	103-W-09	525.2	09/19/19 11:04	Client	09/20/19 10:00
4428906	103-W-10	505	09/19/19 13:08	Client	09/20/19 10:00
4428923	103-W-10	525.2	09/19/19 13:08	Client	09/20/19 10:00
4428907	103-W-11	505	09/19/19 13:12	Client	09/20/19 10:00
4428924	103-W-11	525.2	09/19/19 13:12	Client	09/20/19 10:00
4428908	103-W-12	505	09/19/19 13:17	Client	09/20/19 10:00
4428925	103-W-12	525.2	09/19/19 13:17	Client	09/20/19 10:00
4428909	103-W-13	505	09/19/19 13:23	Client	09/20/19 10:00
4428926	103-W-13	525.2	09/19/19 13:23	Client	09/20/19 10:00
4428910	103-W-14	505	09/19/19 13:30	Client	09/20/19 10:00
4428927	103-W-14	525.2	09/19/19 13:30	Client	09/20/19 10:00
4428911	103-W-15	505	09/19/19 13:39	Client	09/20/19 10:00
4428928	103-W-15	525.2	09/19/19 13:39	Client	09/20/19 10:00
4428912	103-W-16	505	09/19/19 13:43	Client	09/20/19 10:00

4428929	103-W-16	525.2	09/19/19 13:43	Client	09/20/19 10:00
4428913	103-W-17	505	09/19/19 13:52	Client	09/20/19 10:00
4428930	103-W-17	525.2	09/19/19 13:52	Client	09/20/19 10:00

Report Summary

Note: In the Method 525.2 analysis, Anthracene in the LFB (58%) was outside the acceptance limits of 70-130%.

Detailed quantitative results are presented on the following pages. The results presented relate only to the samples provided for analysis.

We appreciate the opportunity to provide you with this analysis. If you have any questions concerning this report, please do not hesitate to call Kelly Blackburn at (574) 233-4777.

Note: This report may not be reproduced, except in full, without written approval from EEA.

(b) (6)

ASM

11/04/2019

Authorized Signature

Title

Date

Client Name: OCCU-TEC Inc.

Report #: 466036

Sampling Point: 103-W-01

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	09/27/19 11:41	09/27/19 23:49	4428897
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	09/27/19 11:41	09/27/19 23:49	4428897
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	09/27/19 11:41	09/27/19 23:49	4428897
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	09/27/19 11:41	09/27/19 23:49	4428897
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/27/19 23:49	4428897
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/27/19 23:49	4428897
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	09/27/19 11:41	09/27/19 23:49	4428897
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	09/27/19 11:41	09/27/19 23:49	4428897
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	09/27/19 11:41	09/27/19 23:49	4428897
83-32-9	Acenaphthene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
206-44-0	Fluoranthene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
90-12-0	1-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
91-57-6	2-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
91-20-3	Naphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 11:27	4428914

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

\$ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-02

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	09/27/19 11:41	09/28/19 01:02	4428898
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	09/27/19 11:41	09/28/19 01:02	4428898
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	09/27/19 11:41	09/28/19 01:02	4428898
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	09/27/19 11:41	09/28/19 01:02	4428898
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 01:02	4428898
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 01:02	4428898
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	09/27/19 11:41	09/28/19 01:02	4428898
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 01:02	4428898
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	09/27/19 11:41	09/28/19 01:02	4428898
83-32-9	Acenaphthene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
206-44-0	Fluoranthene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
90-12-0	1-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
91-57-6	2-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
91-20-3	Naphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:08	4428915

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

\$ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-03

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	09/27/19 11:41	09/28/19 01:26	4428899
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	09/27/19 11:41	09/28/19 01:26	4428899
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	09/27/19 11:41	09/28/19 01:26	4428899
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	09/27/19 11:41	09/28/19 01:26	4428899
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 01:26	4428899
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 01:26	4428899
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	09/27/19 11:41	09/28/19 01:26	4428899
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 01:26	4428899
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	09/27/19 11:41	09/28/19 01:26	4428899
83-32-9	Acenaphthene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
206-44-0	Fluoranthene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
90-12-0	1-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
91-57-6	2-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
91-20-3	Naphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 12:49	4428916

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

\$ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-04

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	09/27/19 11:41	09/28/19 01:50	4428900
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	09/27/19 11:41	09/28/19 01:50	4428900
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	09/27/19 11:41	09/28/19 01:50	4428900
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	09/27/19 11:41	09/28/19 01:50	4428900
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 01:50	4428900
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 01:50	4428900
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	09/27/19 11:41	09/28/19 01:50	4428900
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 01:50	4428900
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	09/27/19 11:41	09/28/19 01:50	4428900
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 13:30	4428917

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-05

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	09/27/19 11:41	09/28/19 02:14	4428901
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	09/27/19 11:41	09/28/19 02:14	4428901
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	09/27/19 11:41	09/28/19 02:14	4428901
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	09/27/19 11:41	09/28/19 02:14	4428901
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 02:14	4428901
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 02:14	4428901
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	09/27/19 11:41	09/28/19 02:14	4428901
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 02:14	4428901
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	09/27/19 11:41	09/28/19 02:14	4428901
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:10	4428918

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-06

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	09/27/19 11:41	09/28/19 02:38	4428902
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	09/27/19 11:41	09/28/19 02:38	4428902
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	09/27/19 11:41	09/28/19 02:38	4428902
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	09/27/19 11:41	09/28/19 02:38	4428902
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 02:38	4428902
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 02:38	4428902
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	09/27/19 11:41	09/28/19 02:38	4428902
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 02:38	4428902
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	09/27/19 11:41	09/28/19 02:38	4428902
83-32-9	Acenaphthene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
206-44-0	Fluoranthene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
90-12-0	1-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
91-57-6	2-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
91-20-3	Naphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 14:51	4428919

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

\$ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-07

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	09/27/19 11:41	09/28/19 03:02	4428903
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	09/27/19 11:41	09/28/19 03:02	4428903
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	09/27/19 11:41	09/28/19 03:02	4428903
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	09/27/19 11:41	09/28/19 03:02	4428903
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 03:02	4428903
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 03:02	4428903
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	09/27/19 11:41	09/28/19 03:02	4428903
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 03:02	4428903
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	09/27/19 11:41	09/28/19 03:02	4428903
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 15:32	4428920

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-08

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	09/27/19 11:41	09/28/19 03:27	4428904
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	09/27/19 11:41	09/28/19 03:27	4428904
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	09/27/19 11:41	09/28/19 03:27	4428904
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	09/27/19 11:41	09/28/19 03:27	4428904
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 03:27	4428904
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 03:27	4428904
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	09/27/19 11:41	09/28/19 03:27	4428904
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	09/27/19 11:41	09/28/19 03:27	4428904
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	09/27/19 11:41	09/28/19 03:27	4428904
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:12	4428921

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-09

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	10/01/19 12:23	10/02/19 04:51	4428905
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	10/01/19 12:23	10/02/19 04:51	4428905
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	10/01/19 12:23	10/02/19 04:51	4428905
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	10/01/19 12:23	10/02/19 04:51	4428905
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	10/01/19 12:23	10/02/19 04:51	4428905
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	10/01/19 12:23	10/02/19 04:51	4428905
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	10/01/19 12:23	10/02/19 04:51	4428905
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	10/01/19 12:23	10/02/19 04:51	4428905
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	10/01/19 12:23	10/02/19 04:51	4428905
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 16:53	4428922

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-10

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	10/02/19 12:41	10/02/19 21:10	4428906
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	10/02/19 12:41	10/02/19 21:10	4428906
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	10/02/19 12:41	10/02/19 21:10	4428906
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	10/02/19 12:41	10/02/19 21:10	4428906
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 21:10	4428906
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 21:10	4428906
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	10/02/19 12:41	10/02/19 21:10	4428906
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 21:10	4428906
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	10/02/19 12:41	10/02/19 21:10	4428906
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 17:34	4428923

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-11

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	10/02/19 12:41	10/02/19 21:35	4428907
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	10/02/19 12:41	10/02/19 21:35	4428907
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	10/02/19 12:41	10/02/19 21:35	4428907
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	10/02/19 12:41	10/02/19 21:35	4428907
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 21:35	4428907
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 21:35	4428907
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	10/02/19 12:41	10/02/19 21:35	4428907
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 21:35	4428907
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	10/02/19 12:41	10/02/19 21:35	4428907
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/06/19 18:14	4428924

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-12

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	10/02/19 12:41	10/02/19 22:49	4428908
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	10/02/19 12:41	10/02/19 22:49	4428908
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	10/02/19 12:41	10/02/19 22:49	4428908
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	10/02/19 12:41	10/02/19 22:49	4428908
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 22:49	4428908
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 22:49	4428908
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	10/02/19 12:41	10/02/19 22:49	4428908
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 22:49	4428908
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	10/02/19 12:41	10/02/19 22:49	4428908
83-32-9	Acenaphthene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
206-44-0	Fluoranthene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
90-12-0	1-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
91-57-6	2-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
91-20-3	Naphthalene \$	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 00:33	4428925

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

\$ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-13

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	10/02/19 12:41	10/02/19 23:13	4428909
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	10/02/19 12:41	10/02/19 23:13	4428909
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	10/02/19 12:41	10/02/19 23:13	4428909
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	10/02/19 12:41	10/02/19 23:13	4428909
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 23:13	4428909
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 23:13	4428909
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	10/02/19 12:41	10/02/19 23:13	4428909
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 23:13	4428909
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	10/02/19 12:41	10/02/19 23:13	4428909
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:15	4428926

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-14

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	10/02/19 12:41	10/02/19 23:38	4428910
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	10/02/19 12:41	10/02/19 23:38	4428910
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	10/02/19 12:41	10/02/19 23:38	4428910
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	10/02/19 12:41	10/02/19 23:38	4428910
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 23:38	4428910
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 23:38	4428910
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	10/02/19 12:41	10/02/19 23:38	4428910
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	10/02/19 12:41	10/02/19 23:38	4428910
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	10/02/19 12:41	10/02/19 23:38	4428910
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 01:57	4428927

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-15

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	10/02/19 12:41	10/03/19 00:03	4428911
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	10/02/19 12:41	10/03/19 00:03	4428911
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	10/02/19 12:41	10/03/19 00:03	4428911
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	10/02/19 12:41	10/03/19 00:03	4428911
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/03/19 00:03	4428911
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/03/19 00:03	4428911
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	10/02/19 12:41	10/03/19 00:03	4428911
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	10/02/19 12:41	10/03/19 00:03	4428911
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	10/02/19 12:41	10/03/19 00:03	4428911
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 02:39	4428928

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-16

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	10/02/19 12:41	10/03/19 00:28	4428912
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	10/02/19 12:41	10/03/19 00:28	4428912
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	10/02/19 12:41	10/03/19 00:28	4428912
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	10/02/19 12:41	10/03/19 00:28	4428912
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/03/19 00:28	4428912
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/03/19 00:28	4428912
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	10/02/19 12:41	10/03/19 00:28	4428912
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	10/02/19 12:41	10/03/19 00:28	4428912
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	10/02/19 12:41	10/03/19 00:28	4428912
83-32-9	Acenaphthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
206-44-0	Fluoranthene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
90-12-0	1-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
91-57-6	2-Methylnaphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
91-20-3	Naphthalene §	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	10/03/19 08:44	10/11/19 03:21	4428929

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

§ The state of origin does not offer certification for this parameter.

Sampling Point: 103-W-17

PWS ID: Not Supplied

Semi-volatile Organic Chemicals									
Analyte ID #	Analyte	Method	Reg Limit	MRL†	Result	Units	Preparation Date	Analyzed	EEA ID #
12674-11-2	Aroclor 1016	505	---	0.08	< 0.08	ug/L	10/02/19 12:41	10/03/19 00:53	4428913
11104-28-2	Aroclor 1221	505	---	0.19	< 0.19	ug/L	10/02/19 12:41	10/03/19 00:53	4428913
11141-16-5	Aroclor 1232	505	---	0.23	< 0.23	ug/L	10/02/19 12:41	10/03/19 00:53	4428913
53469-21-9	Aroclor 1242	505	---	0.26	< 0.26	ug/L	10/02/19 12:41	10/03/19 00:53	4428913
12672-29-6	Aroclor 1248	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/03/19 00:53	4428913
11097-69-1	Aroclor 1254	505	---	0.1	< 0.1	ug/L	10/02/19 12:41	10/03/19 00:53	4428913
11096-82-5	Aroclor 1260	505	---	0.2	< 0.2	ug/L	10/02/19 12:41	10/03/19 00:53	4428913
57-74-9	Chlordane	505	2 *	0.1	< 0.1	ug/L	10/02/19 12:41	10/03/19 00:53	4428913
8001-35-2	Toxaphene	505	3 *	1.0	< 1.0	ug/L	10/02/19 12:41	10/03/19 00:53	4428913
83-32-9	Acenaphthene \$	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
208-96-8	Acenaphthylene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
120-12-7	Anthracene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
56-55-3	Benzo(a)anthracene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
205-99-2	Benzo(b)fluoranthene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
207-08-9	Benzo(k)fluoranthene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
191-24-2	Benzo(g,h,i)perylene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
50-32-8	Benzo(a)pyrene	525.2	0.2 *	0.02	< 0.02	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
218-01-9	Chrysene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
53-70-3	Dibenzo(a,h)anthracene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
206-44-0	Fluoranthene \$	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
86-73-7	Fluorene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
193-39-5	Indeno(1,2,3-cd)pyrene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
90-12-0	1-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
91-57-6	2-Methylnaphthalene \$	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
91-20-3	Naphthalene \$	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
85-01-8	Phenanthrene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930
129-00-0	Pyrene	525.2	---	0.1	< 0.1	ug/L	09/24/19 08:25	10/01/19 07:09	4428930

Any positive Aroclor result would require analysis for total PCB as decachlorobiphenyl by method 508A (MCL = 0.5 ug/L)

\$ The state of origin does not offer certification for this parameter.

† EEA has demonstrated it can achieve these report limits in reagent water, but can not document them in all sample matrices.

Reg Limit Type:	MCL	SMCL	AL
Symbol:	*	^	!

Lab Definitions

Continuing Calibration Check Standard (CCC) / Continuing Calibration Verification (CCV) / Initial Calibration Verification Standard (ICV) / Initial Performance Check (IPC) - is a standard containing one or more of the target analytes that is prepared from the same standards used to calibrate the instrument. This standard is used to verify the calibration curve at the beginning of each analytical sequence, and may also be analyzed throughout and at the end of the sequence. The concentration of continuing standards may be varied, when prescribed by the reference method, so that the range of the calibration curve is verified on a regular basis. CCL, CCM, and CCH are the CCC standards at low, mid, and high concentration levels, respectively.

Internal Standards (IS) - are pure compounds with properties similar to the analytes of interest, which are added to field samples or extracts, calibration standards, and quality control standards at a known concentration. They are used to measure the relative responses of the analytes of interest and surrogates in the sample, calibration standard or quality control standard.

Laboratory Duplicate (LD) - is a field sample aliquot taken from the same sample container in the laboratory and analyzed separately using identical procedures. Analysis of laboratory duplicates provides a measure of the precision of the laboratory procedures.

Laboratory Fortified Blank (LFB) / Laboratory Control Sample (LCS) - is an aliquot of reagent water to which known concentrations of the analytes of interest are added. The LFB is analyzed exactly the same as the field samples. LFBs are used to determine whether the method is in control. FBL, FBM, and FBH are the LFB samples at low, mid, and high concentration levels, respectively.

Laboratory Method Blank (LMB) / Laboratory Reagent Blank (LRB) - is a sample of reagent water included in the sample batch analyzed in the same way as the associated field samples. The LMB is used to determine if method analytes or other background contamination have been introduced during the preparation or analytical procedure. The LMB is analyzed exactly the same as the field samples.

Laboratory Trip Blank (LTB) / Field Reagent Blank (FRB) - is a sample of laboratory reagent water placed in a sample container in the laboratory and treated as a field sample, including storage, preservation, and all analytical procedures. The FRB/LTB container follows the collection bottles to and from the collection site, but the FRB/LTB is not opened at any time during the trip. The FRB/LTB is primarily a travel blank used to verify that the samples were not contaminated during shipment.

Matrix Spike Duplicate Sample (MSD) / Laboratory Fortified Sample Matrix Duplicate (LFSMD) - is a sample aliquot taken from the same field sample source as the Matrix Spike Sample to which known quantities of the analytes of interest are added in the laboratory. The MSD is analyzed exactly the same as the field samples. Analysis of the MSD provides a measure of the precision of the laboratory procedures in a specific matrix. SDL, SDM, and SDH / LFSMDL, LFSMDM, and LFSMDH are the MSD or LFSMD at low, mid, and high concentration levels, respectively.

Matrix Spike Sample (MS) / Laboratory Fortified Sample Matrix (LFSM) - is a sample aliquot taken from field sample source to which known quantities of the analytes of interest are added in the laboratory. The MS is analyzed exactly the same as the field samples. The purpose is to demonstrate recovery of the analytes from a sample matrix to determine if the specific matrix contributes bias to the analytical results. MSL, MSM, and MSH / LFSML, LFSMM, and LFSMH are the MS or LFSM at low, mid, and high concentration levels, respectively.

Quality Control Standard (QCS) / Second Source Calibration Verification (SSCV) - is a solution containing known concentrations of the analytes of interest prepared from a source different from the source of the calibration standards. The solution is obtained from a second manufacturer or lot if the lot can be demonstrated by the manufacturer as prepared independently from other lots. The QCS sample is analyzed using the same procedures as field samples. The QCS is used as a check on the calibration standards used in the method on a routine basis.

Reporting Limit Check (RLC) / Initial Calibration Check Standard (ICCS) - is a procedural standard that is analyzed each day to evaluate instrument performance at or below the minimum reporting limit (MRL).

Surrogate Standard (SS) / Surrogate Analyte (SUR) - is a pure compound with properties similar to the analytes of interest, which is highly unlikely to be found in any field sample, that is added to the field samples, calibration standards, blanks and quality control standards before sample preparation. The SS is used to evaluate the efficiency of the sample preparation process.



Eaton Analytical

110 S. Hill Street
South Bend, IN 46617
T: 1.800.332.4345
F: 1.574.233.8207

Order # 376893
Batch # 466096

www.EurofinsUS.com/Eaton

Shaded area for EEA use only

REPORT TO: Kevin Herford
kherford@acutec.com

BILL TO: OCCU-TEC

CHAIN OF CUSTODY RECORD

Page 1 of 2

LAB Number	COLLECTION		SAMPLER (Signature)	COMPLIANCE MONITORING	SAMPLING SITE	TEST NAME	PWS ID #	STATE (sample origin)		PROJECT NAME	CHLORINATED		# OF CONTAINERS	MATRIX CODE	TURNDOWN TIME
	DATE	TIME						AM	PM		YES	NO			
897	9/19/14	9:03	X		103-W-01	SDS-PATHs and SDS-PLB	N/A	MO	6FL-103	X		4	DW SW		
898		9:07	X		103-W-02					X					
899		9:13	X		103-W-03					X					
900		9:21	X		103-W-04					X					
901		9:26	X		103-W-05					X					
902		9:31	X		103-W-06					X					
903		9:34	X		103-W-07					X					
904		9:41	X		103-W-08					X					
905		11:01	X		103-W-09 Dme SDS Lab Broke in Transit ID					X					
906		13:09			103-W-10					X					
907		13:12			103-W-11					X					
908		13:17			103-W-12					X					
909		13:23			103-W-13					X					
910		13:30			103-W-14					X					

LAB RESERVES THE RIGHT TO RETURN UNUSED PORTIONS OF NON-AQUEOUS SAMPLES TO CLIENT

RELINQUISHED BY: (Signature) [Signature] DATE 9/19/14 TIME 1700 AM | PM

RECEIVED BY: (Signature) [Signature] DATE _____ TIME _____ AM | PM

RECEIVED FOR LABORATORY BY: [Signature] DATE 9-20-14 TIME 1000 AM | PM

CONDITIONS UPON RECEIPT (check one):
 Ice/Wet/Blue Ambient _____ °C Upon Receipt _____ NIA

LAB COMMENTS: S.2
J.L.B
S.L.B
3.0

MATRIX CODES:
 DW-DRINKING WATER
 RW-REAGENT WATER
 GW-GROUND WATER
 EW-EXPOSURE WATER
 SW-SURFACE WATER
 PW-POOL WATER
 WW-WASTE WATER

TURN-AROUND TIME (TAT) - SURCHARGES:
 SW = Standard Written: (15 working days) 0%
 RV = Rush Verbal: (5 working days) 50%
 RW = Rush Written: (5 working days) 75%

IV* = Immediate Verbal: (3 working days) 100%
 IW* = Immediate Written: (3 working days) 125%
 SP* = Weekend, Holiday CALL
 STAT* = Less than 48 hours CALL

* Please call, expedited service not available for all testing

Sample analysis will be provided according to the standard EEA Water Services Terms, which are available upon request. Any other terms proposed by Customer are deemed material alterations and are rejected unless expressly agreed to in writing by EEA.



Eaton Analytical

110 S. Hill Street
South Bend, IN 46617
T: 1.800.332.4345
F: 1.574.233.8207

Order # 376893
Batch # _____

www.EurofinsUS.com/Eaton

CHAIN OF CUSTODY RECORD

Page 1 of 2

REPORT TO: Kevin Herford
 Kherford@ocutec.com
 BILL TO: OCU-TEC

SAMPLER (Signature) [Redacted]
 COMPLIANCE MONITORING: YES NO

PWS ID # N/A STATE (sample origin) MO PROJECT NAME 6FL-103

POPULATION SERVED N/A SOURCE WATER N/A

CHLORINATED: YES NO

OF CONTAINERS 4 MATRIX CODE _____

TURNAROUND TIME _____

LAB Number	COLLECTION		SAMPLING SITE	TEST NAME	SAMPLE REMARKS	CHLORINATED		# OF CONTAINERS	MATRIX CODE	TURNAROUND TIME
	DATE	TIME				YES	NO			
914	9/19/19	9:03	103-W-01	<u>SOS - PARTS and SOS - PUB</u>		X	X	4	<u>NW SW</u>	
915		9:07	103-W-02			X	X			
916		9:13	103-W-03			X	X			
917		9:21	103-W-04			X	X			
918		9:26	103-W-05			X	X			
919		9:31	103-W-06			X	X			
920		9:39	103-W-07			X	X			
921		9:47	103-W-08			X	X			
922		11:04	103-W-09	<u>Dine SOS - line broken in transit ED</u>		X	X			
923		13:04	103-W-10			X	X			
924		13:12	103-W-11			X	X			
925		13:17	103-W-12			X	X			
926		13:23	103-W-13			X	X			
927		13:30	103-W-14			X	X			

RELINQUISHED BY: (Signature) [Redacted] DATE 9/19/19 TIME 17:00

RECEIVED BY: (Signature) [Redacted] DATE _____ TIME _____

RECEIVED FOR LABORATORY BY: [Redacted] DATE 9-20-19 TIME 10:00

LAB COMMENTS: S.7
J.6
S.6
3.0

CONDITIONS UPON RECEIPT (check one):
 Iced/Wet/Blue
 Ambient _____ °C Upon Receipt _____ N/A

MATRIX CODES:
 DW-DRINKING WATER
 RW-REAGENT WATER
 GW-GROUND WATER
 EW-EXPOSURE WATER
 SW-SURFACE WATER
 PW-POOL WATER
 WW-WASTE WATER

TURN-AROUND TIME (TAT) - SURCHARGES:
 SW = Standard Written: (15 working days) 0%
 RV* = Rush Verbal: (5 working days) 50%
 RW* = Rush Written: (5 working days) 75%

IV* = Immediate Verbal: (3 working days) 100%
 IW* = Immediate Written: (3 working days) 125%
 SP* = Weekend, Holiday CALL
 STAT* = Less than 48 hours CALL

* Please call, expedited service not available for all testing

Sample analysis will be provided according to the standard EEA Water Services Terms, which are available upon request. Any other terms proposed by Customer are deemed material alterations and are rejected unless expressly agreed to in writing by EEA.



Eaton Analytical

110 S. Hill Street
South Bend, IN 46617
T: 1.800.332.4345
F: 1.574.233.8207

Order # 374093
Batch # _____

www.EurofinsUS.com/Eaton

Shaded area for EEA use only

CHAIN OF CUSTODY RECORD

Page 2 of 2

REPORT TO:	SAMPLER (Signature)	PWS ID #		STATE (sample origin)	PROJECT NAME	PO#	# OF CONTAINERS	MATRIX CODE	TURNAROUND TIME
		COMPLIANCE MONITORING	POPULATION SERVED						
BILL TO:		Yes	No						
LAB Number		SAMPLING SITE			TEST NAME	SAMPLE REMARKS	CHLORINATED		
							YES	NO	
1	4428, 928	DATE	TIME	AM	PM	X			
2	929	9/19/19	13:39			X			
3	930	13:43				X			
4		13:52				X			
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									

RELINQUISHED BY: (Signature)	DATE	TIME	RECEIVED BY: (Signature)	DATE	TIME	LAB COMMENTS
	9/19/19	1700				LAB RESERVES THE RIGHT TO RETURN UNUSED PORTIONS OF NON-AQUEOUS SAMPLES TO CLIENT
RELINQUISHED BY: (Signature)	DATE	TIME	RECEIVED BY: (Signature)	DATE	TIME	CONDITIONS UPON RECEIPT (check one): Iced: <input checked="" type="checkbox"/> Wet/Blue: <input type="checkbox"/> Ambient: <input type="checkbox"/> °C Upon Receipt: _____ N/A
				9-20-19	1000	
RELINQUISHED BY: (Signature)	DATE	TIME	RECEIVED FOR LABORATORY BY:	DATE	TIME	

MATRIX CODES:
 DW-DRINKING WATER
 RW-REAGENT WATER
 GW-GROUND WATER
 EW-EXPOSURE WATER
 SW-SURFACE WATER
 PW-POOL WATER
 WW-WASTE WATER

IV* = Immediate Verbal: (3 working days) 100%
 IW* = Immediate Written: (3 working days) 125%
 SP* = Weekend, Holiday
 STAT* = Less than 48 hours

* Please call, expedited service not available for all testing

Sample analysis will be provided according to the standard EEA Water Services Terms, which are available upon request. Any other terms proposed by Customer are deemed material alterations and are rejected unless expressly agreed to in writing by EEA.